

Declaration of conformity

according to Directive 2010/35/EU
for a pressure equipment

The manufacturer

Shaoxing Xieli Fire Safety Equipment Co., Ltd.
ADD: Wufu Village ,Yiting Town ,Shangyu City, Zhejiang Province ,312353,P.R.China
Tel: +86-575-82412358 Fax: +86-575-82417770

herewith declares, that the pressure equipment

Description:	Steel Gas Cylinders
Year of manufacture:	2020
Type-, serial, identification-No:	Φ 137-5L No.00001-00304
Chamber designation:	--
max. allowable pressure PW:	200bar
allowable min./max. temperature TS:	-40 °C
Volume V / Diameter DN:	5L
Test pressure PH:	315bar
Date of pressure test:	2020-05
Pressure test medium:	Water
Fluid - fluidgroup:	I & II

complies with the requirements of the Pressure Equipment Directive 2010/35/EU.

Applied conformity assessment
procedures: *Type approval(module B)+Initial inspection tests*

Applied standards and technical
specifications: EN ISO 9809-1: 2010

Other applied EC-Directives: --

Engaged notified bodies

Surveillance of the QS-System:
Examination / inspections / test during
manufacturing: ISO9001: 2008 issued by CQC

Certificates which are included

EC-Design Examination Certificate No.:
EC-Type Examination Certificate No.: 0036-048-16 Rev.0
EC-Certificate of conformity No.:

Location, Date: shangyu,2020-05-04
TÜV SÜD - PED Professional

